

NATIONAL ELECTRICAL CODE CHANGES



- 1. Every entrance and exit to/from a room requires a switch controlled lighting outlet.**
- 2. If switched outlets are used rather than an overhead light then parts of two (2) or more outlets must be switched.**
- 3. SE/SER Cable not allowed to be exposed on exterior. (services must be in PVC-EMT-RMC).**
- 4. Living areas must be strapped prior to installing cable.**
- 5. Three way switches (S3) must be pilot lighted and not placed over a stair.**