



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

Laboratory Report

Town of Sandown Rec Dept.
PO Box 642, Attn: Recreation Dept.
Sandown, NH 03873

Date Printed: 07/26/2021
Work Order #: 2107-03954
Client Job #:
Date Received: 07/23/2021
Sample collected in: New Hampshire

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:
Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:
Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. None
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: Data Qualifier (DQ) Flags: None

SAMPLE STATE SPECIFIC NOTES:

Additional Narrative or Comments: None

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.



Donald A. D'Anjou, Ph. D.
Laboratory Director

A & L Laboratory: Accreditations: Maine ME00021, New Hampshire 2501, Maine Radon Registration ID # SPC20
Granite State Analytical Services, LLC: Accreditations: New Hampshire 1015; Maine NH00003;
Massachusetts M-NH0003; Rhode Island 101513; Vermont VT-101507



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038

Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

CERTIFICATE OF ANALYSIS FOR RECREATIONAL WATER

Legend

DATE PRINTED: 07/26/2021
CLIENT NAME: Town of Sandown Rec Dept.
CLIENT ADDRESS: PO Box 642, Attn: Recreation Dept.
Sandown, NH 03873

Passes ✓
Fails EPA Primary ⊗
Fails EPA Secondary ▼
Fails State Guideline ✕
Attention ▲

SAMPLE ID #: 2107-03954-001
SAMPLED BY: Mike D.

DATE AND TIME COLLECTED: 07/23/2021 04:00PM

DATE AND TIME RECEIVED: 07/23/2021 04:27PM

ANALYSIS PACKAGE: MPN-Beach

RECEIPT TEMPERATURE: 25.2° CELSIUS

CLIENT JOB #:

SAMPLE LOCATION: Seeley Beach
Sandown NH 03873

MORE LOC INFO:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date - Time Analyzed
E. coli MPN	25.9	MPN/100mL	✓		1	88	SM 9223B	CE-NH	07/24/2021 04:52PM
Total Coliform / E.coli Bacteria Preparation (Colifert® Quanti-Tray®) 20th ED SM 9223B DG-NH 07/23/2021 04:34PM									



Donald A. D'Anjou

Donald A. D'Anjou, Ph. D.
Laboratory Director