

MAY - 7 2015

SELECTMEN'S OFFICE
TOWN OF SANDOWN NH

GRANITE STATE ANALYTICAL SERVICES, LL

22 Manchester Street, Unit 2, Derry, NH 03038

Phone (800) 699-9920

(603) 432-3044

Fax (603) 432-3044

http://www.granitestateanalytical.com/

DATE PRINTED: 04/30/2015

Legend

CLIENT NAME: Town of Sandown Rec Dept.

Passes

CLIENT ADDRESS: PO Box 642, Attn: Recreation Dept.
Sandown, NH 03873

Fails EPA Pri

Fails EPA Sec

Fails EPA Pro

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

SAMPLE ID#: 1504-01812-002

DATE AND TIME COLLECTED: 04/29/2015

SAMPLED BY: Client-Customer

DATE AND TIME RECEIVED: 04/29/2015

ANALYSIS PACKAGE: Bac P/A

SAMPLE LOCATION: Ball Field

RECEIPT TEMPERATURE: ON ICE 17.1

Test Description	Results	Test Units	Pass / Fail	EPA Limit	Method	Analyst	Date
Coliform Bacteria*	Absent	P-A/100mL	✓	Absent	SM 9223B	BB-NH	04/29/
E. coli Bacteria*	Absent	P-A/100mL	✓	Absent	SM 9223B	BB-NH	04/29/

The results presented in this report relate to the samples listed above in the condition in which they were received.

* NEIAC Accredited Analysis

IN ACCORDANCE