



GRANITE STATE ANALYTICAL SERVICES, LLC

22 Manchester Road, Unit 2, Derry, NH 03038

Phone (800) 699-9920

(603) 432-3044

Fax (603) 434-4837

<http://www.granitestateanalytical.com/>

CERTIFICATE OF ANALYSIS

DATE PRINTED: 08/03/2017
CLIENT NAME: Town of Sandown Rec Dept.
CLIENT ADDRESS: PO Box 642, Attn: Recreation Dept.
Sandown, NH 03873

RECEIPT TEMPERATURE: ON ICE 25.1° CELSIUS

SAMPLE ID#: 1708-00340-001
SAMPLED BY: Client-Customer
SAMPLE SITE: MPN Beach

DATE AND TIME COLLECTED: 08/02/2017 10:20AM
DATE AND TIME RECEIVED: 08/02/2017 12:53PM
SAMPLE LOCATION: Seeley Beach

CLIENT JOB

Test Description	Results	Test Units	DQ Flag	LOQ (RL)	Method	Analyst	Date & Time Analyzed
E. coli MPN	28.8	MPN/100 mL	J	1	SM 9223B	CW-NH	08/02/17 3:52PM

The results presented in this report relate to the samples listed above in the condition in which they were received.

RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.

Data Qualifier (DQ) Flags: J = Estimated concentration.

Note: Bacteria sample contained less than the method required minimum sample volume of 100mL.

* NELAP Accredited Analysis



Donald A. D'Anjou, Ph. D.
Laboratory Director

This analysis meets NELAP requirements except as noted.

State Certifications: | NH 1015 | MA M-NH003 | ME NH00003 | RI 101513 | VT VT-101507 |

This certificate shall not be reproduced, except in full, without the written approval of Granite State Analytical Services, LLC