



GRANITE STATE

ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038

Phone: (800) 699-9920 | (603) 432-3044

website: www.granitestateanalytical.com

DATE PRINTED: 03/13/2019

LEAD RESULTS

LAB ID#: 1015

COMPLIANCE PERIOD: CHEMICAL RESULTS FOR THE QUARTER 2019

SYSTEM NAME: EDWARD C GARVEY REC BLDG

SYSTEM TOWN: Sandown

SAMPLE CATEGORY: Routine Sample

SAMPLING AGENT: Mencis, Edward

SAMPLE AGENT #: 603-867-6085

RECEIPT TEMP: 14.4° CELSIUS

SAMPLE LOCATION

Legend	
Passes	✓
Fails EPA Primary	✗
Fails EPA Secondary	⚠
Fails State Guideline	✗
Attention	⚠

EPA ID #: 2087020

WATER SYSTEM TYPE: Non-Transient, Non-Community

TEST UNITS: mg/L ANALYST: CW-NH

METHOD: EPA 200.8

MCL: 0.015 mg/L

MDL (RL): 0.001 mg/L

DATE & TIME RECEIVED: 03/08/2019 9:57AM

REC CENTER

FIREHOUSE KITCHEN

TOWN HALL

DATE/TIME COLLECTED	LABORATORY SAMPLE ID#	CLIENT JOB #	LEAD *	Pass /Fail	DATE ANALYZED
03/08/2019 8:20AM	1903-00667-001		<0.001	✓	03/12/19
03/08/2019 8:00AM	1903-00667-002		0.0041	✓	03/12/19
03/08/2019 8:10AM	1903-00667-003		0.0016	✓	03/12/19

The results presented in this report relate to the samples listed above in the condition in which they were received.
RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.

Data Qualifier (DQ) Flags: None

* NELAP Accredited Analysis



Donald A. D'Anjou, Ph. D.
Laboratory Director